



## NOTES

1. SEE MN/DOT PLATE NO. 7036 FOR A.D.A. REQUIREMENTS FOR SIZE, SLOPE, LOCATION AND TRUNCATED DOME AREA GUIDELINES.
- ② IF RAMP IS PAID BY SQ. FT. THEN TRUNCATED DOME AREA IS PAID IN ADDITION TO RAMP AREA.
- ③ E.J. = 1/2" PREFORMED JOINT FILLER PER MN/DOT SPEC. 3702.
4. RAMP THICKNESS IS TO BE MIN. 6" CONCRETE—MN/DOT SPEC. MIX 3A32 WITH A MIN. OF 4" AGGREGATE BASE CLASS 2 (INCIDENTAL).
5. PRECAST TRUNCATED DOME MATERIAL SHALL BE APPROVED BY THE ENGINEER.

DEPARTMENT OF PUBLIC WORKS CITY OF ROCHESTER, MINNESOTA			
<b>PEDESTRIAN CURB RAMP</b>			
<i>Donald Nelson</i> ASST. CITY ENGINEER		<i>Richard W. Finner</i> DIRECTOR	
SHT 1 OF 2 SHTS	DATE REVISED 3/22/06	PLATE NO. 2-13	REV. H

